- 1.1 Standards All new brick work including, but not limited to, expansion joints, ties and fasteners and accessories shall conform to standards of the Brick Institute of America.
- 1.2

- 2.12 Air space between brick and wall shall be a minimum of 1 ½".
- 2.13 Glazed brick or ceramic tile on restroom walls: A minimum of five feet high is preferred.
- 2.14 Copper wall flashing: A minimum of 5 oz. shall extend below the entire width of the brick.
- 2.15 Bricks used for paving shall be of a grade designated as suitable for ground contact.
- 2.16 Store masonry units on elevated platforms in a dry location. If units are not stored in an enclosed location, cover tops and sides of stacks with waterproof sheeting and ensure that they are securely tied. If units become wet, do not install until they are dry.
- 3.1 Thru-wall flashiny aretore 9.002 Tw 11.04 -0 0 11.04 57.j1.5 (t)-3 (o)-6.5.92 Tm (e9.002 Tw 11.5 all (e s)1.7 (ec)1.1(r)1