

Louisiana State University Design Standards

DIVISION 10 – SPECIALTIES

1 VISUAL DISPLAY SURFACES

- 1.1 Glass marker boards must be provided by a single manufacturer.
- 1.2 1/4" Tempered safety writing glass, polished with eased corners
- 1.3 Size of white marker board shall be 48 inches in height at all locations.
 - 1.3.1 Repair and preparation of existing wall surfaces to which these boards are to be attached and to make ready for the installation of this work is a requirement. The University prefers metal trim bulletin, chalk boards
 - 2.2 Standard heights for boards will be 37" above the floor

3 RESTROOMS

- 3.1 The University prefers floor supported head rail braced toilet partitions.
 - 3.1.1 Do not use a ceiling hung partition unless enclosed on each side with a wall. Partitions and doors shall be solid phenolic resin core, solid plastic or solid color reinforced composite.
- 3.2 Partitions layout shall comply with ADA requirements. All hardware shall be type 304 stainless steel and door hinges shall be field adjustable to be self-closing or partially open when unoccupied.
- 3.3 Dispensers—Jumbo Bath Tissue Dispensers, Paper Towel Dispensers and Soap Dispensers will be furnished by The University and installed by the contractor as per ADA guidelines.
- 3.4 Jumbo (12") Bath Tissue Dispensers furnished by The University will be Georgia- Pacific 59012.
- 3.5